

Proposed Code Change State Form 41186R

RETURN TO: INDIANA DEPARTMENT OF HOMELAND SECURITY CODE SERVICES SECTION 302 W. Washington Street Room W246

Indianapolis, IN 46204

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY - Dashed line through material to be deleted, underline material to be added)

FOR OFFICE USE ONLY

Received 5/9/09

Code 53-09

Use second sheet for any material re	equiring more space.	
Code Title		Edition
Indiana Residential Code		2009
Section number and title		Page
G2411.1.1		526
Proponent Title		
Charlie Eldridge Consultant		
Address		Phone
551 Grassy Ln., Indianapolis, IN 46217		(317) 370-3444
PROPOSED CODE CHANGE (Check One)		
Change to read as follows Add to read as follows Delete and substitute as follows Delete without substitution G2411.1.1 (310.1.1) CSST. All metal gas piping upstream from the equipment shutoff valve(s) shall be electrically continuous and shall be bonded to an effective ground-fault current path in accordance with Section E3509.7. Except where connected to appliances and at bonding connections, corrugated stainless steel piping shall be isolated from other metal gas piping, metal water piping, metal air ducts, metal structural framing, and all electrical wiring methods by a space separation of at least 2 inches. Table E3603.1, or the piping system listing requirements, shall be used to size the bonding conductor used to bond corrugated stainless steel gas tubing (CSST) to the electrical system.		
DEACON AND FIGURE IMPACT		
REASON AND FISCAL IMPACT This text was extracted from the 2005 Indiana Residential Code. Also, in my opinion, the bonding of all piping systems should be		
done with the bonding jumper sized the same as the grounding electrode conductor. In most of the homes today, that would entail a piece of #4 Cu. (200 ampere service) from the service equipment to the CSST manifold.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		